

ਨੰਬਰ 1054/139

5th 2/16

ਨਗਰ ਨਿਗਮ, ਅੰਮ੍ਰਿਤਸਰ।

ਵਾਟਰ ਸਪਲਾਈ ਅਤੇ ਸੀਵਰੇਜ ਵਿਭਾਗ

ਤਸਦੀਕ ਕੀਤਾ ਜਾਂਦਾ ਹੈ ਕਿ Alexandra ਸਕੂਲ ਸਿਹਤਾ ਕਿ
ਗਲੀ ਕਵੀਨਸ ਰੋਡ, ਅੰਮ੍ਰਿਤਸਰ ਵਿਖੇ ਸਥਿਤ ਹੈ। ਇਸ ਸਕੂਲ ਦਾ ਪੀਣ ਵਾਲਾ ਪਾਣੀ
ਨਗਰ ਨਿਗਮ, ਅੰਮ੍ਰਿਤਸਰ ਦੀ ਵਾਟਰ ਟੈਸਟਿੰਗ ਲਾਬੋਰਟਰੀ ਵਲੋਂ ਚੈਕ ਕਰਨ
ਉਪਰੰਤ ਸਵੱਛ ਅਤੇ ਪੀਣ ਯੋਗ ਪਾਇਆ ਗਿਆ ਹੈ।

ਇਹ ਸਰਟੀਫਿਕੇਟ ਸਾਲ 2016-17 ਲਈ ਹੈ।

ਵਾਟਰ ਸਪਲਾਈ ਅਤੇ ਸੀਵਰੇਜ ਵਿਭਾਗ
ਨਗਰ ਨਿਗਮ, ਅੰਮ੍ਰਿਤਸਰ

14/5/16

DISTRICT WATER TESTING LABORATORY / MOBILE WATER TESTING LABORATORY DEPARTMENT OF W/S & SANITATION, PUNJAB

ANALYSIS REPORT OF WATER SAMPLE AMRITSAR Sample No. 269

Particular of Sample

1. Name of Place /Alexandra School 8 Quarna Road Amritsar
 District ASA Block Village Location

2. Source of the sample (Tick) Canal / Tubewell / Hand Pump / Any Other Hand Pump

3. Name / Designation of the person who collected the sample *Praveen / Alexandra School / Amritsar*

4. (i) Date & Time of receipt in the Lab *15/9/2020*
 (ii) Commencement of Test *16/9/2020*

5. Type of Disinfection (Tick) Silver Ionization / Chlorination / None

Sr. No.	Test	Desirable Limit	Permissible Limit	Result
1	Turbidity (NTU) Max	5.0	10	NIL
2	Colour (Visual)	---	Un objectionable	Colorless
3	Taste & Odour (Qualitative)	---	Un objectionable	Odourless
4	pH	6.5 to 8.5	No relaxation	7.8
5	Total Dissolved Solids mg / l Max.	500	2000	250
6	Total Alkalinity (as Ca, CO ₃), mg/l, Max	200	600	244
7	Total Hardness (as Ca, CO ₃), mg/l, Max	300	600	248
8	Calcium (Ca), mg/l, Max.	75	200	56
9	Chloride Mg/l. Max.	250	1000	24
10	Residual Chlorine (as Cl), mg/l, Max.	0.2	0.5	---
11	Fluorides (as F), mg/l, Max	1.0	1.5	0.15
12	Nitrate (as NO ₃), mg/l, Max	45	100	---
13	Sulphate (as SO ₄), mg/l, Max	200	400	33
14	Iron (as Fe), mg/l	0.3	1.0	NIL

Bacteriological Parameters :

1. Test for Total Coliform by MPN method with Maconky Broth 10m/
 1m/x
 C.1m/x

2. Test for Fecal Coliform by MPN method with Aq Broth (Conducted if Total Coliform present)

Report :

1. The water is potable / not potable →
2. The following parameters are more than the Desirable limit but last than the permissible limit. (Sample not drawn by us. Unless and other wise stated)

[Signature]
In charge,
 District Water Testing Laboratory,
 /Mobile Water Testing Laboratory
 AMRITSAR

DISTRICT WATER TESTING LABORATORY / MOBILE WATER TESTING LABORATORY DEPARTMENT OF W/S & SANITATION, PUNJAB

ANALYSIS REPORT OF WATER SAMPLE AMRITSAR Sample No. 467

Particular of Sample

1. Name of Place Alexandria School Amritsar
 District Asa Block _____ Village _____ Location _____
 2. Source of the sample (Tick) Canal / Tubewell / Hand Pump / Any Other S/Pump
 3. Name / Designation of the person who collected the sample Prinapal Alexandria School Amritsar
 4. (i) Date & Time of receipt in the Lab 19/6/2017
 (ii) Commencement of Test 20/6/2017
 5. Type of Disinfection (Tick) _____ Silver Ionization / Chlorination / None


Test	Desirable Limit	Permissible Limit	Result
1. Turbidity (NTU) Max	5.0	10	Nil
2. Colour (Visual)	—	Un objectionable	Colourless
3. Taste & Odour (Qualitative)	—	Un objectionable	Odourless
4. pH	6.5 to 8.5	No relaxation	7.8
5. Total Dissolved Solids mg / l Max.	500	2000	256
6. Total Alkalinity (as Ca, CO ₃), mg/l, Max	200	600	247
7. Total Hardness (as Ca, CO ₃), mg/l, Max	300	600	248
8. Calcium (Ca), mg/l, Max.	75	200	56
9. Chloride Mg/l. Max.	250	1000	—
10. Residual Chlorine (as Cl), mg/l, Max.	0.2	0.5	—
11. Fluorides (as F), mg/l, Max	1.0	1.5	0.15
12. Nitrate (as NO ₃), mg/l, Max	45	100	—
13. Sulphate (as SO ₄), mg/l, Max	200	400	36
14. Iron (as Fe), mg/l	0.3	1.0	Nil

Bacteriological Parameters :

- Test for Total Coliform by MPN method with Maconky Broth
 - 10ml/
 - 1m/x
 - C.1m/x
2. Test for Fecal Coliform by MPN method with Aq Broth (Conducted if Total Coliform present)

Report :

- The water is potable / not potable
- The following parameters are more than the Desirable limit but last than the permissible limit. (Sample not drawn by us. Unless and other wise stated)


 In charge,
 District Water Testing Laboratory
 / Mobile Water Testing Laboratory
 AMRITSAR

DISTRICT WATER TESTING LABORATORY / MOBILE WATER TESTING LABORATORY DEPARTMENT OF W/S & SANITATION, PUNJAB

ANALYSIS REPORT OF WATER SAMPLE
AMRITSAR

Sample No. 387

Particular of Sample

1. Name of Place Alexandria School Amritsar
 District Asa Block _____ Village _____ Location _____
 2. Source of the sample (Tick) Canal / Tubewell / Hand Pump / Any Other Hand Pump
 3. Name / Designation of the person who collected the sample Block Pi / Ed. Education officer Amritsar
 4. (i) Date & Time of receipt in the Lab 26/2/2018
 (ii) Commencement of Test 29/2/2018
 5. Type of Disinfection (Tick) Silver Ionization / Chlorination / None


Sr. No.	Test	Desirable Limit	Permissible Limit	Result
1.	Turbidity (NTU) Max	5.0	10	NIL
2.	Colour (Visual)	---	Un objectionable	Colourless
3.	Taste & Odour (Qualitative)	---	Un objectionable	Ordinary
4.	pH	6.5 to 8.5	No relaxation	7.6
5.	Total Dissolved Solids mg / l Max.	500	2000	260
6.	Total Alkalinity (as Ca, CO ₃), mg/l, Max	200	600	236
7.	Total Hardness (as Ca, CO ₃), mg/l, Max	300	600	240
8.	Calcium (Ca), mg/l, Max.	75	200	52
9.	Chloride Mg/l. Max.	250	1000	32
10.	Residual Chlorine (as Cl), mg/l, Max.	0.2	0.5	—
11.	Fluorides (as F), mg/l, Max	1.0	1.5	0.13
12.	Nitrate (as NO ₃), mg/l, Max	45	100	—
13.	Sulphate (as SO ₄), mg/l, Max	200	400	26
14.	Iron (as Fe), mg/l	0.3	1.0	NIL

Bacteriological Parameters :

1. Test for Total Coliform by MPN method with Maconky Broth 10m/
 1m/x
 C.1m/x
2. Test for Fecal Coliform by MPN method with Aq Broth
 (Conducted if Total Coliform present)

Report :

1. The water is potable / not-potable _____
 2. The following parameters are more than the Desirable limit but last than the permissible limit. _____
 (Sample not drawn by us. Unless and other wise stated)


 In charge,
 District Water Testing Laborat
 /Mobile Water Testing Laborat
 AMRITSAR